


GREEN ENERGY

COMBUSTION PLANT WITH ROTARY KILN FOR SPECIAL BIOMASSES AND M.B.M. (MEAT AND BONE MEAL) WITH SUPERHEATED STEAM GENERATOR AND CONDENSATION STEAM TURBINE # FRB -EE



MODEL	FRB - EE		
TREATED WASTE TYPE	SPECIAL BIOMASSES AND		
	M.B.M. (MEAT AND BONE MEAL)		
INCINERATION CAPACITY	1.000 -2.000 Kg/h		
COMBUSTION CHAMBER	COUNTER-CURRENT ROTARY		
	KILN		
OPERATING TIME	CONTINUOUS		
FEEDING SYSTEM	AUTOMATIC		
OPERATNG HOURS PER DAY	24 h.		
WASTE HEATING POWER	16,8 MJ/Kg – MAXIMUM		
	HUMIDITY 20%		
HEAT RECOVERY	SUPERHEATED STEAM		
RECOVERED HEAT	3,5 – 7 MWt		
POTENTIALITY			
POWER SUPPLY POTENTIALITY	0.5 1.0.8404/0		
FROM CONDENSATION	0,5 – 1,0 MWe		
FLUE GAS CLEANING	DRY SCRUBBING WITH BAGS		
	FILTER (Bicarbonate + activated		
	carbon)		

The proposed combustion system is designed to meet the emission limits required and enforced by the EU Standard # 2000/76/EU Guide line

The combustion plant for special biomasses and M.B.M. (meat and bone meal) is based on a counter-current rotary kiln. The plant is available in different capacity per hour type with the following features:

- Continuous automatic feeding system with screw conveyor
- Counter-current rotary kiln with controlled temperature (*virtually a pyrolysis under sub-stoichiometric conditions*) complete with burner and control board. Unloading of ashes is automatic and continuous.
- Post combustion chamber is designed to grant:
 - Temperature of 850/1.050 °C
 - Combustion gas residence time from > 0,5 to 2 seconds
 - Swirl chamber to improve combustion's efficiency
 - Oxygen content > 6%

Complete with burner, control board and emergency chimney.

- Hot water pipes type heat exchanger for the production of superheated steam at 45 bar T=450°C –
- Flue gas cleaning system for the abatement of pollutants acid fumes, dioxins and heavy metals dry scrubbing type using bicarbonate and activated carbons. The system is supplied complete with reactor, reagent's dosing and bags filter.

- PLC control unit complete with dedicated operating system and net connection for online assisted technical support
- Condensation steam turbine, complete with power supply generator, condenser, evaporation tower and accessories.


ТҮРЕ	QUANTITY	½ HOUR VALUE	DAILY AVERAGE VALUE
DUSTS	mg/Nm ³	30	10
HCI	mg/Nm ³	60	10
SO ₂ +SO ₃ as SO ₂	mg/Nm ³	200	50
HF	mg/Nm ³	4	1
NO _X as NO ₂	mg/Nm ³	400	250
CO	mg/Nm ³	100	50
T.O.C.	mg/Nm ³	20	10
ТҮРЕ	QUANTITY	PROBE AVERAGE VALUE	
Hg	mg/Nm ³	0,5	
Cd + Tl	mg/Nm ³	0,05	
Pb + Cr + Cu + Sn + Mn + Sb + As +Ni + V	mg/Nm ³	0,5	
DIOXINS + DI-BENZOFURANS (2,3,7,8 TCDD)	mg/Nm ³	0,1 Average value over a sampling period of 8 hours	

The results of the measurements made to verify compliance with the emission limits are standardized at the following conditions:

- TEMPERATURE 273,15 K
- PRESSURE 101.3 kPa
- STATE OF GAS MEASURED DRY
- CONTENT OF OXYGEN IN THE FLOWING GAS EQUAL TO 11% IN VOLUME

Sound pressure level 1 meter away from the logic perimeter of the source (i.e. the *entire combustion system including its bases*):

■ 85 dB +/- 2 dB MAX



Note: The technical data are only indicative and need to be checked in the design phase.